

- 1. It is necessary to ensure the minimum dimensions shown are suitable for the existing ground conditions. *Engineering advice may be required.* 2. A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pockets.
- A minimum concrete strength of 3000 PSI is recommended. The concrete should be vibrated to eliminate air pock
 The finished level of the concrete surround must be approx. 1/8" above the top of the channel edge.
- The missing level of the concrete surround must be approx. 1/8" above the top of the c
 Refer to ACO'S latest installation instructions for complete details.
- 5. Concrete base thickness should match slab thickness.

ACO	SPECIFICATION CLAUSE ACO Polymer Products P.O. Box 245 Chardon, OH 44024 PH: 440.285,7000	ACO Polymer Products Inc. P.O. Box 245 Chardon, OH 44024 PH: 440-285-7000
DRWG# 1802 Date: 3,12,07 WWW.ACOUSA.COM	TD100 Traffic Drain System	FX: 440-285-8517 e-mail: sales@acousa.com

<u>General</u>

The surface drainage system shall be ACO ROAD TraffikDrain complete with gratings as manufactured by ACO Polymer Products, Inc.

<u>Materials</u>

The trench system bodies shall be manufactured from polymer concrete with minimum properties as follows: Compressive strength of 14,000psi; Flexural strength of 4,000psi; Water absorption shall not exceed 0.07% by weight. Trench system shall be resistant to prolonged salt exposure, repetitive frost cycles and chemically resistant to dilute acids and alkalis.

The nominal clear opening shall be 4.00" (100mm) with overall width of 6.375" (160mm). Modular units shall be manufactured with either an invert slope of 0.6% or with neutral invert and have a minimum wall thickness of at least 0.67" (16mm). Each unit will feature a full radius in the trench bottom and a male to female interconnecting end profile. Units shall have horizontal cast in anchoring features on the outside wall to ensure maximum mechanical bond to the surrounding bedding material and pavement surface. The ductile iron edge rail will be integrally cast in by the manufacturer to ensure maximum homogeneity between polymer concrete body and edge rail. Each edge rail shall be at least $\frac{1}{4}$ " (6mm) thick.

<u>Grates</u>

Grates are manufactured from ductile to ASTM A536-84 and shall be certified to load class E600 as defined byDIN 19580 / EN1433. Grates feature 60% open area or 38.92 sq inches for maximum hydraulic effeciency. Each grate shall be secured by two bolts and two locking lugs. After removal of grates there shall be uninterrupted access to the trench to aid maintenance.

Installation:

The surface drain system shall be installed in accordance with the manufacturer's installation instructions and drawings.